

## LOC Questions and Clarifications Memorandum

---

**To:** Solicited Vendors for Letter of Configuration (LOC) Number 39100, dated January 9, 2014 for the Mississippi State Crime Lab

**From:** Craig P. Orgeron, Ph.D. <sup>CA</sup>

**Date:** January 17, 2014

**Subject:** Responses to Questions Submitted and Clarifications to Specifications

**Contact Name:** Chris Nix

**Contact Phone Number:** 601-432-8041

**Contact E-mail Address:** Chris.Nix@its.ms.gov

---

**LOC Number 39100 is hereby amended as follows:**

1. The paragraph from page one has been changed to read: "The Mississippi Department of Information Technology Services (ITS) is seeking the purchase and installation of inside and outside communications cabling ~~without termination~~ described below on behalf of the Mississippi Department of Public Safety (DPS). Our records indicate that your company currently has a valid proposal on file at ITS in response to General RFP #3608 for ITS Cabling. Our preliminary review of this proposal indicates that your company offers products, software, and/or services that may meet the requirements of this project; therefore, we are requesting your configuration assistance for the components described below."
2. Item 5.16 is being modified to read: Vendor must provide and install 25 pair copper feeder cable with lightning protection from the Telecommunications room on second floor to the Telecommunications room in the records and storage building utilizing the existing underground conduit system. Vendor to determine distance.
3. Item 5.24 is being modified to read: Vendor must provide and install five 19" wide and 7' tall 42" deep black APC enclosed racks cabinets with vertical and horizontal wire management in the second floor Telecommunications Room. ~~Each rack must be secured to the floor with lag bolts.~~
4. Item 5.34 is being added: Vendor must provide and install 5 coax drops per floor for CATV. All coax cables will terminate in the second floor Telecommunications Room.

Vendor must include in the proposal a response to each amended requirement as listed above. Vendor must respond using the same terminology as provided in the original requirements.

The following question was submitted to ITS and is being presented as it was submitted, except to remove any reference to a specific vendor. This information should assist you in formulating your response.

**Question 1:** Do you want the LIU in the EF wall mounted?

**Response:** Yes. All equipment shall be wall mounted in the Entrance Facility (EF).

LOC responses are due January 22, 2014, at 3:00 p.m. (Central Time).

If you have any questions concerning the information above or if we can be of further assistance, please contact Chris Nix at 601-432-8041 or via email at [Chris.Nix@its.ms.gov](mailto:Chris.Nix@its.ms.gov).

cc: ITS Project File Number 39100